



## NZDU01940 Dulux Weathershield Semi Gloss on New Masonry [Exterior]

### Scope of Works

DULUX Weathershield X10 Semi Gloss is a 100% acrylic self priming paint for exterior use. Its unique MaxiFlex Stretch Technology gives a tough, flexible finish for long life protection from the extremes of weather.

### **Substrate and Substrate Preparation**

#### **Substrate Notes**

This is a generic masonry and cementitious substrate. It includes concrete block substrates. The following substrates are excluded: Precast, Tilt-up and Off-form, Concrete Flooring, Roof Tiles and Cement Render. Other specialty masonry or cementitious substrates may also not be covered by this substrate.

#### BRICK

Bricks are predominantly kiln-fired clay, which can be glazed or unglazed. The glazing on glazed bricks should be ground or scabbled to improve adhesion of the coating system. Brickwork is often raked, so rendering requires much more material than face-laid brickwork. The surface must be clean and sound, free of dirt, grime, mould, fungus, stains, powdery mortar smears and all other contaminants. The surface should be examined to determine if it has been laid to specification (flush jointed or face laid) and that the surface variation is within acceptable tolerances. If applying a texture coating, the degree to which the texture coating camouflages flush walls depends on how flush the substrate has been constructed.

### **BLOCKWORK**

Blockwork is largely cement based and highly porous, and usually flush-laid. The surface should be examined to determine if it has been laid to specification (flush jointed or face laid) and that the surface variation is within acceptable tolerances. The degree to which texture coatings camouflage flush walls depends on how flush the substrate has been constructed.

### AUTOCLAVED AERATED CONCRETE (AAC)

AAC is manufactured from sand, lime and cement, to which is added water and aluminium paste. After mixing, the cement slurry is poured into moulds. The aluminium paste reacts with the alkaline elements in the mixture and forms hydrogen gas. This liberated gas expands the mixture forming extremely small finely dispersed air spaces. The product is removed from the mould after a few hours, cut to the required dimension and finally cured under pressure in a steam autoclave.

AAC Block Wall Systems are (typically) load-bearing external wall solutions for homes as an alternative to traditional double brick construction. Blocks are glued together (thin bed) using AAC Manufacturer's adhesive to a design standard of providing a level, fully filled joint.

AAC Panel is (typically) a 50 or 75mm panel of Autoclaved Aerated Concrete (AAC) with corrosion protected steel reinforcement embedded during production. This lightweight, yet solid masonry panel is designed for external cladding in timber or steel frame construction. Panels are glued together (thin bed) using AAC Manufacturer's adhesive to a design standard of providing a level, fully filled joint.

### Substrate Preparation Notes

### ASSESS SUITABILITY

Concrete, mortar and cement based products need to be fully cured for at least 28 days before painting, unless using Dulux AcraTex HAR primer.

### PREPARE SURFACE

Remove any powdery layers, laitance, efflorescence and protrusions of mortar by detergent cleaning, wire brushing, water blasting or a suitable chemical treatment.

### CLEAN

Clean the surface thoroughly by water blasting or detergent cleaning, where a commercial cleaner is added to hot or cold water and surface is washed / scrubbed thoroughly with a stiff bristle broom and then rinsed clean with fresh water. This may need to be repeated on extremely dirty surfaces to ensure removal of efflorescence or other poorly bonded surface material. Ensure that the surface is dry, clean and free from dust. Efflorescence may also be removed with an acid treatment, followed by washing down the surface with water.

### REPAIR SURFACE IMPERFECTIONS

Fill any cracks or surface imperfections with a suitable filler or patching compound.

### RENDERING OF NEW BRICK/ BLOCKWORK & MASONRY

Refer to Dulux AcraTex Texture coatings for suitable levelling and texture systems.





Coating System Su	ımmary
<ul><li>1st Coat</li><li>2nd Coat</li><li>3rd Coat</li></ul>	Dulux 1 Step Prep Water Based Primer Sealer Undercoat Dulux Weathershield Semi Gloss Dulux Weathershield Semi Gloss
Coating System	

Coating System						
1st Coat — Dulux 1 Step Pre	Water Ba	ased Primer Se	aler Undercoat			
Coat Type 1st Coat		Datasheet NZDU00432 I	Datasheet NZDU00432 Dulux 1 Step Prep Water Based Primer Sealer Undercoat			
Read the full Datasheet details at	Dulux 1 St	<u>ep Prep Water B</u>	ased Primer Sealer Underco	a <u>t</u>		
Application Methods						
Air Spray 🛉 Airless	Spray	<b>Brush</b>	Roller			
	Min		Max	Reco	ommended	
Theoretical Spread Rate (m²/L)				14		
Wet Film Per Coat (microns)				71		
Dry Film Per Coat (microns)				31		
Recoat Time **	2 Hour	s				
V.O.C. Level < 40g/L untinted			Meets ECNZ V.O. Not Applicable	Meets ECNZ V.O.C. Requirements?  Not Applicable		
ROLLER: Using a medium nap rolle Stir contents thoroughly before an AIRLESS/CONVENTIONAL SPRAY: to aid atomisation. BRUSH: Wet brushes with water pi When painting exterior surfaces, e	d during us Suitable for	e. r application by allo o avoid clogging.	ll standard spray equipment. Apply a full even coat direct	If necessary thin with up		
SDS Number DLXNZLEN002997			SDS Link View SDS Link			
2nd Coat — Dulux Weathersh	ield Semi	Gloss				
Coat Type 2nd Coat		Datasheet NZDU00242	Datasheet NZDU00242 Dulux Weathershield Semi Gloss			
Read the full Datasheet details at	: <u>Dulux We</u> a	athershield Semi	Gloss			
Application Methods						
Air Spray 🛉 Airless	s Spray	<b>Brush</b>	<b>7</b> Roller			
	Min		Max	Reco	ommended	
Theoretical Spread Rate (m²/L)	16		16	16		
Wet Film Per Coat (microns)	63		63	63		





Dry Film Per Coat (microns)	25	25	25	
Recoat Time **	2 Hours	Indefinite		
V.O.C. Level < 60 g/L untinted		Meets ECNZ V.O.C. Requirements?  Yes  Total Volatile Organic Content (TVO accordance to the stated methodolo Manuals. The TVOC content is theory of the known VOC values of the pro These materials include the base par required for non-factory packaged of the state of the process of the proce	ogy within Green Star Technical retically calculated as the sum total oduct's raw material components. iint plus additional low VOC tinter	
action.  Brush/Roller Soak brush or roller in water before Airless or Conventional Spray Suitable for application by all stand Under hot or very windy condition surfaces, apply 2 coats of Weather Weathershield Chromamax Pigment apply 1 coat of Dulux 1Step prep-	e starting and use while still slightly da dard spray equipment. Apply wet eve s, up to 100 ml/litre of DULUX Hot We shield. Some colours may require mon the Bases (True Red, Bold Yellow, Orang coat. iron, Zincalume	fore and during use with a broad flat st amp. Thinning is usually not required. In coats. If necessary thin with up to 10 eather Thinner may be added to ease a re than the recommended number of c ge, Blue and Extra Bright bases), when thershield. Preparation/coating system	0 ml/litre water to aid atomisation. application. On previously painted coats to achieve full opacity. For painting over contrasting colour,	
quality and conditions of pre-prim- advice, please call Dulux Help & A humid days. Exposure to rain or ov time of the day, cool the surface b Steel/wrought iron	ed timber/fibre cement, Colorbond® dvice on 0800 800 424 for specific gu	& Colorsteel® and tilt-up & precast co lidance. Check the weather forecast. Do in the coating being damaged or remo the shady side of the house.	oncrete surfaces. For help and on not paint on excessively cold or	
Bare surfaces including brick, ma Apply 3 coats of Weathershield.				
	or Weathershield Chromamax Pigmen mer followed by 2 topcoats of Weathe	t Bases (True Red, Bold Yellow, Orange ershield.	e, Blue and Extra Bright bases),	
		t Bases (True Red, Bold Yellow, Orange ershield.	e, Blue and Extra Bright bases),	
improved resistance to cracking o		t Bases (True Red, Bold Yellow, Orange a coat of Dulux 1Step Prepcoat prior to eets to qualify for guarantee.		
SDS Number DLXNZLEN003378				
3rd Coat — Dulux Weathershield Semi Gloss				

3rd Coat — Dulux Weathershield Semi Gloss		
Coat Type  3rd Coat  Datasheet  NZDU00242 Dulux Weathershield Semi Gloss		
Read the full Datasheet details at <u>Dulux Weat</u>	thershield Semi Gloss	
Application Methods		
Air Spray 🛉 Airless Spray	Brush Roller	





	Min	Max	Recommended
Theoretical Spread Rate (m²/L)	16	16	16
Wet Film Per Coat (microns)	63	63	63
Dry Film Per Coat (microns)	25	25	25
Recoat Time **	2 Hours	Indefinite	
V.O.C. Level < 60 g/L untinted		Meets ECNZ V.O.C. Requirements?  Yes  Total Volatile Organic Content (TVOC accordance to the stated methodolog Manuals. The TVOC content is theore of the known VOC values of the prod These materials include the base pair required for non-factory packaged contents.	y within Green Star Technical tically calculated as the sum total uct's raw material components. It plus additional low VOC tinter

### Coating Application Details

Brush, roller, conventional and airless spray. Stir contents thoroughly before and during use with a broad flat stirrer, using an upward lifting action.

### Brush/Roller

Soak brush or roller in water before starting and use while still slightly damp. Thinning is usually not required.

### Airless or Conventional Spray

Suitable for application by all standard spray equipment. Apply wet even coats. If necessary thin with up to 100 ml/litre water to aid atomisation. Under hot or very windy conditions, up to 100 ml/litre of DULUX Hot Weather Thinner may be added to ease application. On previously painted surfaces, apply 2 coats of Weathershield. Some colours may require more than the recommended number of coats to achieve full opacity. For Weathershield Chromamax Pigment Bases (True Red, Bold Yellow, Orange, Blue and Extra Bright bases), when painting over contrasting colour, apply 1 coat of Dulux 1Step prep-coat.

### Within 1km of sea for galvanised iron, Zincalume

Apply one coat of Dulux All Metal Primer followed by 2 topcoats of Weathershield. Preparation/coating system can vary depending on the quality and conditions of pre-primed timber/fibre cement, Colorbond® & Colorsteel® and tilt-up & precast concrete surfaces. For help and advice, please call Dulux Help & Advice on 0800 800 424 for specific guidance. Check the weather forecast. Do not paint on excessively cold or humid days. Exposure to rain or overnight dew whilst drying may result in the coating being damaged or removed. If painting during the hottest time of the day, cool the surface by hosing before painting and paint on the shady side of the house.

### Steel/wrought iron

Apply 2 coat of Dulux All Metal Primer followed by 2 topcoats of Weathershield.

### Bare surfaces including brick, masonry, fibre cement, Zincalume

Apply 3 coats of Weathershield.

### Galvanised iron

Apply 3 coats of Weathershield. For Weathershield Chromamax Pigment Bases (True Red, Bold Yellow, Orange, Blue and Extra Bright bases), apply 1 coat of Dulux All Metal Primer followed by 2 topcoats of Weathershield.

## For Zincalume/galvanised iron roofs

Apply 3 coats of Weathershield. For Weathershield Chromamax Pigment Bases (True Red, Bold Yellow, Orange, Blue and Extra Bright bases), apply 1 coat of Dulux All Metal Primer followed by 2 topcoats of Weathershield.

### Bare unpainted timber

Apply 3 coats of Weathershield. For Weathershield Chromamax Pigment Bases (True Red, Bold Yellow, Orange, Blue and Extra Bright bases), for improved resistance to cracking on hardwoods (eg Mt Ash, Oak), apply a coat of Dulux 1Step Prepcoat prior to the application of two topcoats of Weathershield. Professional Painters refer to Duspec Specification Sheets to qualify for guarantee.

SDS Number	SDS Link
DLXNZLEN003378	<u>View SDS Link</u>

### Coating System Notes

\* Practical Spreading Rate will vary from the quoted Theoretical Spreading Rate due to factors such as method and condition of application and surface roughness. \*\* Recoat times are quotes for 25°c and 50% relative humidity, these may vary under different conditions.





### Disclaimer

This Specification is copyright to DuluxGroup (Australia) Pty Ltd and/or DuluxGroup (New Zealand) Pty Ltd (collectively, 'Dulux'). It may not be varied or altered without the prior written consent of Dulux, and if it is, Dulux has no responsibility or liability for those variations.

Unless Dulux has provided you with a customised, project-specific specification, this Duspec+ document does not represent that any particular product or product system will be suitable for your project.

Any information provided in this Duspec+ is given in good faith and is believed by Dulux to be correct at the time of publication. Products and coating systems can be expected to perform as indicated in this Duspec+ document, provided the substrate is in good condition, the coatings are applied by a suitably experienced and skilled applicator, and the preparation, application and maintenance is followed strictly as set out in this Duspec+ document, and as recommended on the applicable Dulux Product Data Sheet and Safety Data Sheets for the relevant products (available from <a href="https://www.duspecplus.co.nz">www.duspecplus.co.nz</a>). Climatic conditions at application time can affect Duspec+ documentation suitability and product performance.

The correct colour or colour match is the responsibility of the applicator. Colours will change over time and Dulux does not guarantee that the same colour newly mixed will match a colour applied earlier which has been subjected to weathering or other change elements. No product colour is guaranteed against colour change.

Where any liability of Dulux in respect of this Specification cannot by law be excluded, Dulux's liability is limited, as permitted by law and at Dulux's option, to resupply of the relevant products or services or to reimbursing the cost of those products or services.

WHERE LEAD MAY BE PRESENT: The asset manager is responsible for verifying the presence of lead and determining whether to remove or encapsulate the lead. If lead is present, the work must be done in strict accordance with AS/ NZS 4361 Parts 1 and 2 and Worksafe Australia or New Zealand guidelines.